





FUSION



TOM CAMPBELL



NICOLE STAMMER



MARY TAYLOR



COLLEEN AYDELOTTE



CAMILLE STEFANI



HOLLY DAVIA



JOSH WALKER



BRI BASILE


Through a collaborative team dynamic, Fusion delivered a state of the art medical center in line with the Children's Hospital and Medical Center's mission. The building facilitates exceptional clinical care to improve the life of every child. With a multi-disciplinary and integrative approach, the Team created a center of wellness that adapts to the changing needs of the hospital community.


























































































































Fume Exhaust System



























Backup Power






Redundant
Backup Power




On-Site Generation























































Perform Site Analysis and Develop Establish Team **Project Goals** Integration Design **Ensure Project** and Themes Strategies Strategizing Outcome






Table of Contents

Slide Number

Goal Development

Team Structure

Design Strategizing

Design Development

05

Project Outcome



Develop
Project Goals
and Themes





Project Themes









Reduce Energy Load

Community Icon



Resilient Engineering

Dual Functionality Spaces

Community Shelter



Medical Staff Efficiency

Patient Security

Building Performance Monitoring































Meet Budget

Optimize Schedule

High-Performance Façade

Smart Building Technology

Disasters Preparedness

Meets Future Needs

50+ Year Lifespan

Flexibility in Use

Minimize Building Impact

Community Icon

Disaster Relief

Patient Security

Enhance Patient Experience

Efficiency of Care

High Air Quality Standards

Regulate Circadian Rhythm

Project Delivery Method

Collaborative Environment


Design Strategizing

Workflow Organization

Decision Making

Establish Team Integration Strategies










Mock Up and VR Space



Collaborative Work Space






















Subcommittee

Team Health and KPI Survey





Software Interoperability & BIM

Online Pull Planning






Team Calendar

Bluebeam Studio

Workflow Planning







Team Health and KPI Survey



Software Interoperability & BIM




Team Calendar




Online Pull Planning




Bluebeam Studio







Subcommittee



Team Health and KPI Survey



Software Interoperability & BIM




Team Calendar



Online Pull Planning




Bluebeam Studio





3



Subcommittee



Team Health and **KPI Survey**



Software Interoperability & BIM




Team Calendar


Online Pull

Planning

Bluebeam Studio









Subcommittee

Team Health and **KPI Survey**






Software Interoperability & BIM

Online Pull Planning





Team Calendar Bluebeam Studio




















Subcommittee

Team Health and KPI Survey





Software Interoperability & BIM

Online Pull Planning






Team Calendar

Bluebeam Studio

Google Calendar




















Subcommittee

Team Health and KPI Survey





Software Interoperability & BIM


Online Pull Planning





Team Calendar

Bluebeam Studio


























Project Goals

Goal Categories



Weighting Scale:

- High Importance
- Medium Importance
- Low Importance



Professional Input

Site Analysis

Resilient Strategies

Best Practices

Perform Site
Analysis and Design
Strategizing





PennState Health
Milton S. Hershey
Medical Center



Michele Smith
Clinical Leader
Hershey Medical Center




Timothy Dunkle
Assistant Director of
Facilities
Hershey Medical Center



Eileen Wiley
Assistant Director, Facilities
Planning and Construction
Hershey Medical Center



Catherine Brower
Assistant Director, Facilities
Planning and Construction
Hershey Medical Center



Line of Site to Patients

Ease of Patient Treatment

Efficient Access to Supply Rooms

Provide Room for Students

Family Spaces Close to Patients

Remove Medical Staff Silos


































Ease of Patient Treatment


Patient Control Over Environment
























































































Dodge Street







































































Recorded EF3, EF4, and EF5, Tornados in the United States from 1950 to 2013





 Children's Hospital and Medical Center of Omaha













Storm Shelter Design Wind Speeds, per ICC 500 (2014)



Tornado Intensity

Omaha, Ne.

EF Number	Wind Speed (3 second gust)
EF0	65-85 mph
EF1	86-110 mph
EF2	111-135 mph -
EF3	136-165 mph
EF4	166-200 mph
EF5	>200 mph
	Source: NOAA

ASCE 7-10 Wind Speed Risk Category IV: 120 mph

OMAHA TORNADO MAY 6, 1975 Children's Hospital and Medical Center of Omaha

















































Execute
Design and
Evaluation











Floor Reorganization

Enclosure

75























































Mechanical Room





























































Roof Drains Strainer



Storage Tank

Overflow System

















Roof Drains Strainer


















Roof Drains


















Roof Drains
Strainer
Filtration System
Cooling Tower

Storage Tanks
















Roof Drains Strainer Filtration System **Cooling Tower**


















Roof Drains Strainer Filtration System

Cooling Tower

Storage Tanks

Overflow System

Collection Cistern
























































































- 1.76 MMBtu/hr heating
- 2.14 MMBtu/hr cooling





















































































































Option 2



Option 3






























































36% Cooling Savings


44% Heating Savings























Original Structural Façade Connection















Structural Façade Connection
















































Option 1




\$78.81/SF



Option 2

Resistance to tornadic wind load, minimal resistance to debris impact

\$82.65/SF



Option 3

Significant resistance to tornadic wind load and debris impact

\$129.95/SF




















3/8" Glass

1" Insulated Glazing Unit



1/4" Glass

Lamination


SNX 62/67

1/2" Air Gap


3/8" Glass

IS 20 Coating

Insulated Metal Panel




- Metal Stud Framing
- 22 ga. Steel
- Insulation
- 22 ga. Steel










3/8" Glass

3/4" Laminated Glass 1" Insulated Glazing Unit Insulated Metal Panel



1/4" Glass

Lamination


SNX 62/67

1/2" Air Gap

3/8" Glass




- Metal Stud Framing
- 22 ga. Steel
- Insulation
- 22 ga. Steel










3/16" Glass

3/16" Glass

1" Insulated Glazing Unit Insulated Metal Panel



1/4" Glass

Lamination


SNX 62/67

1/2" Air Gap

3/8" Glass




- Metal Stud Framing
- 22 ga. Steel
- Insulation
- 22 ga. Steel










3/16" Glass

3/16" Glass

3/8" Laminated Glass 1" Insulated Glazing Unit



1/4" Glass

Lamination


SNX 62/67

1/2" Air Gap


3/8" Glass

IS 20 Coating


Insulated Metal Panel




- Metal Stud Framing
- 22 ga. Steel
- Insulation
- 22 ga. Steel










3/8" Glass

3/8" Glass

3/4" Laminated Glass Glass-Clad Polycarbonate



1/4" Glass

5/8" Polycarbonate

1/8" Annealed Glass

SNX 62/67

1/2" Air Gap


3/8" Glass

Lamination


PET Sheet

IS 20 Coating

Insulated Metal Panel



- Metal Stud Framing
- 16 ga. Steel
- Insulation
- 16 ga. Steel










3/8" Glass

3/4" Laminated Glass Glass-Clad Polycarbonate Insulated Metal Panel



1/4" Glass

5/8" Polycarbonate

1/8" Annealed Glass

SNX 62/67

1/2" Air Gap

3/8" Glass

Lamination


PET Sheet







- 16 ga. Steel
- Insulation
- 16 ga. Steel








3/8" Glass

Lamination

3/8" Glass



1/4" Glass

5/8" Polycarbonate

1/8" Annealed Glass

SNX 62/67


1/2" Air Gap

3/8" Glass

Lamination

PET Sheet







- Metal Stud Framing
- 16 ga. Steel
- Insulation
- 16 ga. Steel











\$82.65/SF



Option 3

Significant resistance to tornadic wind load and debris impact

\$129.95/SF




















\$82.65/SF



Option 3

Significant resistance to tornadic wind load and debris impact

\$129.95/SF





























































- Metal Stud Framing
 - 22 ga. Steel
 - Insulation
 - 22 ga. Steel






SNX 62/67

1/2" Air Gap

3/8" Glass

IS 20 Coating





Minimum **3'** Separation

Maximum **30'** Separation



Central Plant

Disaster Preparedness







































































































































CONDENSER WATER










Electric Cooling










































14.5VA/sf x 390,000sf (@ 0.85PF)




4.8MW Design Demand Load




















Voltage drop on cable and bus duct feeders was

limited to 2%



















4MW




Hospital can be powered for

96 hours









Each 480V and 208V branch of the EES are switched separately


per NEC 517.30(B)(2)








































































































Hallway

Team Center

















































Two Seat Charting Station








































































Soiled Hold

Clean Supply Room

Team Center and Collaboration Station

Tube Priming and Medication

Nourishment











SOILED

HOLD. 142 SF











Clean Supply Room




Tube Priming and Medication



Nourishment



Team Center and Collaboration Station




CLINIÇAL

RESEARCH

CHILD LIF

STOR




















Finelite HP-4 Recessed Finelite HP-4 Indirect/Direct






















































Patient Room Tags
























Patient Room Tags



OR and Patient Room Scheduling Software


















Patient Room Tags



Scheduling Software

















Patient Room Tags



KanBan Restocking System




OR and Patient Room Scheduling Software



Patient Room




















STC-52


STC-55

STC-49

STC-39




































Dual Arm Patient Bed

Medical Boom Sikla

Support System





Double Skin Façade




Optimized Design


sDA **27%**

sDA **27%**

sDA **23%**

sDA **37%**











Design Development


















































Tablet for Patient Control


































































































Composite Steel Framing with 4" Concrete Topping on Composite Metal Deck















W18x35 (30)


W18x35 (30)

































	Week 1	Week 2	Week 3	Week 4	Week 5	Week 6	Week 7	Week 8	Week 9
Level 3	P1A1		P1A2	P1A3					
	P1A4		P 1 A5	P1A6					
			P2A1	P2A2		P2A3			
	6.		P2A4	P2A5		P2A6	0.		
				P3A1		P3A2	P3A3	j	
				P3A4		P3A5	P3A6		
		_				P4A1	P4A2		P4A3
						P4A4	P4A5		P4A6

Phase 1	Install & Connect Overhead Racks
Phase 2	Sprinkler & Plumbing Rough-In
Phase 3	Wall Framing & Rough-In
Phase 4	Wall Inspection & Install Gypsum Board





Phase 1	Install & Connect Overhead Racks
Phase 2	Sprinkler & Plumbing Rough-In
Phase 3	Wall Framing & Rough-In
Phase 4	Wall Inspection & Install Gypsum Board

















Milestone Schedule Project Budget


0


LEED

Ensure Project
Outcome











































Primary Energy Savings


kBTU433

Yearly Utilities Savings













Central Plant Relocation








Main Electrical Room














Disaster Preparedness






Mass Casualty Dual Use Spaces




Emergency
Operation Center



Community Shelter




Construction
Disaster Plan





Disaster Preparedness

Floor Reorganization



Mechanical Floor Relocation




Floor Adjacencies



Acoustical Considerations










Disaster Preparedness

Floor Reorganization

Patient Room

Hallway & Team Center




Redesign for Increased Efficiency



Circadian Rhythm



Prefabricated Overhead Racks




Disaster Preparedness

Floor Reorganization

Patient Room


Hallway & Team Center

High-Performance Enclosure






Active Double Skin




Impact Resistance



Dynamic Lighting



Prefabricated Units







Construction



Mechanical



Lighting/Electrical



Structural Appendix | DSF Connection Details
























Structural Appendix | CHP Structural Design






















Texas Tech Wind Science and Engineering Research Cer	nter Construction Mat	erial Threshold Testing Results
Assembly Description	Assembly	Threshold Missile Speed (mph)
2 layers of 3/4" plywood, one layer of 14 ga. steel and 4x4 ft, double stud frame	M M M	<112.8
4" thick pea-gravel concrete with #4 rebar reinforcement 12" O.C. each way	barauhaaauha	162.0











Structural Appendix | Wind Load Calculations





















	Level 9	Roof Pressure Loads (2	200 mpn)		
7000	p (Tabl	e 30.7-2)	Final Design W	ind Pressure (psf)	
Zone	(+)	(-)	(+)	(-)	
1	NA	-187.64	NA	-131.348	
2	NA	-294.49	NA	-206.143	
3	NA	-401.44	NA	-281.008	

Elevation Wind Pressure Loads (200 mph)							
Para I	FLOOP LIFICUT	Hetalar alama	Zone 4		Zone 5		
Level	FLOOR HEIGHT	Height above	(+)	(-)	(+)	(-)	
Roof	14 ft	143.0 ft	89.789	-102.616	89.789	-141.09	
Level 7	14 ft	129.0 ft	87.843	-100.392	87.843	-138.072	
Level 6	14 ft	115.0 ft	85.75	-98	85.75	-134.76	
Level 5	14 ft	101.0 ft	83.468	-95.392	83.468	-131.124	
Level 4	18 ft	87.0 ft	80.871	-92.424	80.871	-127.044	
Level 3	18 ft	69.0 ft	77.028	-88,032	77.028	-120.996	
Level 2	16 ft	51.0 ft	72.24	-82.56	72.24	-113.544	
Level 1	17 ft	35.0 ft	66.64	-76.16	66.64	-104.73	
Lower Level 1	18 ft	18.0 ft	57.96	-66.24	57.96	-91.056	
Lower Level 3	0 ft	0.0 ft	0.00	0.00	0.00	0.00	

Structural Appendix | Mullion Design


AEI TEAM 02-2018 F U S I O N




MULLION DESIGN

Typical mullions were designed as 2-1/2" by 10-1/2". The values on the vertical mullion design charts were extrapolated to the design load of 141 psf.

	Allowable Stress Design Load	LRFD Ultimate Design Load
A =	20 PSF (960)	33 PSF (1580)
B =	30 PSF (1440)	50 PSF (2400)
C =	40 PSF (1920)	67 PSF (3200)
D =	50 PSF (2400)	83 PSF (4000)
E=	60 PSF (2880)	100 PSF (4790)





50	1000	2000	3000	4000	5000	2.2 2.0
40	*		SE'N	/		1.8 1.6 1.4
30	//		1825			1.2
10				Four Sides Si	n.) PVB Lamina mply Supported s. (Load × Are	104
0.0	500	100	00 1	1500	2000	2500

			Plate			
	50 -	50		100	150	200
	00	6 mm (1/4 in.) PV8 Nonfactored Load Four Sides Simply S P _b = 0.008 1 kPa = 20.9 psf 3 Second Duration	i Supported	0.5		3000
rate Width (III)	ŧ	50°C (122°F) 2.50 3.00	1.25		X	2000
	50	5.00	XX	1		1000
	٥	1000		3000 Length (mm) Dimension (in.)		5000
	0	20 40 6.0 mm (1/4 in.) Nonfactored Loa	Plate Long 60 80 Glass d (kPa)	Length (mm) Dimension (in.)	8000 17001	5000
	0	20 40 6.0 mm (1/4 in.) (Nonfactored Loa Four Sides Simply P _a = 0.008	Plate Long 60 80 Glass d (kPa)	Length (mm) Dimension (in.)	140 160	5000
(im.)	140	20 40 6.0 mm (1/4 in.) Nonfactored Loa Four Sides Simply	Plate Long 60 80 Glass d (kPa) supported	Length (mm) Dimension (in.)	140 160	5000
majon (in.)	140	20 40 6.0 mm (1/4 in.) Nonfactored Loa Four Sides Simply P _B = 0.008 1 kPa = 20.9 psf	Plate Long 60 80 Glass d (kPa) supported	Dimension (in.) 100 120	140 160	5000
rt Dimension (in.)	140	20 40 6.0 mm (1/4 in.) Nonfactored Loa Four Sides Simply P _B = 0.008 1 kPa = 20.9 psf	Plate Long 60 80 Glass d (kPa) Supported	Dimension (in.) 100 120	140 160	5000
Short Dimension (in.)	140 120 100	20 40 6.0 mm (1/4 in.) Nonfactored Loa Four Sides Simply P _b = 0.008 1 kPa = 20.9 ppf 3-Second Duration	Plate Long 60 80 Glass d (kPa) Supported	Dimension (in.) 100 120	140 160	5000
Short Dimension (in.)	140 120 100 80	20 40 6.0 mm (1/4 in.) Nonfactored Loa Four Sides Simply P _b = 0.008 1 kPa = 20.9 ppf 3-Second Duration	Plate Long 60 80 Glass d (kPa) Supported	Dimension (in.) 100 120	140 160	5000

3/4" Monolithic Lamin	
L (in)	96
W (in)	84
t (in)	0.75
NFL (kPa)	4.25
NFL (psf)	88.825
Glass Type Factors	4
(Fully Tempered)	4
Load Share Factor	1
Load Resistance (psf)	355.3
IGU Unit Load	255.2
Resistance (psf)	355.3
Required Load	1.11
Resistance (psf)	141

Resistance (ps	f) 141	
	1" IGU	
	Lite 1 (mono)	Lite 2 (lami)
L (in)	48	48
W (in)	84	84
t (in)	0.25	0.25
NFL (kPa)	1.75	1.75
NFL (psf)	36.575	36.575
Glass Type Factors	3.6	3.6
Load Share Factor	0.5	0.5
Load	262.24	262.24

263.34

Resistance (psf)

IGU Unit Load Resistance (psf)

Required Load Resistance (psf)

263.34

263.34

141













Structural Appendix | Foundation Design






n'i		Length (ft)	Compressive	Pile Reinforcing		Pile Cap				
Piles	Top of Piles	(per in field	Strength	Vertical	Ties	Size	Thickness	Reinforcing	Number	
	Lower Level 5	81'-0"				10'-0"×10'-0"		#8 @ 12" O.C. Each Way	19	
	Lower Level 3	103'-0"				10 -0 X10 -0	55″		41	
	Lower Level 5	81'-0"	3000	(4) #8	#3 @ 6" O.C.	13'-6"x15'-0"			22	
	Lower Level 3	103'-0"	3000	(4) #0	#3 @ 0 0.c.	13 -0 X13 -0			7	
	Lower Level 5	81'-0"				13'-6"x20'-0"			22	
	Lower Level 3	103'-0"				13 -0 X20 -0			0	








W21x83

W21x83












Structural Appendix | Lateral Deflection





Wind Deflections						
	Maximum	n Drift (in)	Interstory Drift (in)			
	X	Υ	X	Υ		
Roof	1.02	2.68	0.12	0.33		
Level 7	0.91	2.35	0.12	0.33		
Level 6	0.79	2.02	0.12	0.32		
Level 5	0.67	1.70	0.12	0.32		
Level 4	0.55	1.38	0.15	0.39		
Level 3	0.40	0.99	0.15	0.44		
Level 2	0.26	0.55	0.10	0.23		
Level 1	0.15	0.32	0.09	0.19		
Lower Level 1	0.07	0.13	0.07	0.13		
Lower Level 3	0.00	0.00	0.00	0.00		
		Max	0.15	0.44		

Maximum Building Drift at Tornado Wind Loads					
	Wind Speed	Maximum Drift (in)		Interstory	y Drift (in)
	(mph)	Х	Υ	Х	Υ
ASCE 7-10	120	1.02	2.68	0.15	0.44
F2	135	1.13	2.99	0.16	0.49
F3	165	1.72	4.83	0.25	0.79
F4	200	2.38	6.95	0.34	1.13





















Mechanical Appendix | CHP



Design Option	Total HVAC First Cost	Yearly Operating Cost
Fusion SHP	\$46,275,000	\$1,260,000
Fusion CHP	\$49,930,000	\$835,000

	Per kW	Total Installed		
Base Engine	\$ 2,000	\$ 4,500,000		
Heat Recovery	\$ 500	\$ 900,000		

	Per kWh	Yearly Total		
Maintenance Cost	\$ 0.01	\$ 150,000		

Design Option	Equipment First Cost	Yearly Operating Cost	Simple Payback*
1	\$ 5,295,000	\$ 835,000	11.15
2	\$ 6,855,000	\$ 805,000	13.3
3	\$ 3,850,000	\$ 770,000	8
4	\$ 5,850,000	\$ 846,000	15.6
5	\$ 7,350,000	\$ 808,000	17.7

	Units	C800S	C1000S
Fuel Consumption	[BTU/hr]	8,800,000	11,000,000
Electrical Power Out	[kW]	760	950
Steam Production (9 psig)	[Lb/hr]	3,000	3,300
Electrical Efficiency	[%]	31	31
Recoverable Thermal Efficiency	[%]	39	34
Total Efficiency	[%]	70	65

Design	Microturbine	Mircoturbine	Mircoturbine	Chiller 1	Chiller 2	Chiller 3	Boiler 1*	Boiler 2*	
Option	1	2	3	Cilliei 1	Cilillei 2	Cillier 5	Bullet 1	Bollet 2	
1	1000 KW	800 KW	-	250 Ton (A)	500 Ton (E)	500 Ton (E)	3800 MBH	3800 MBH	
2	800 KW	800 KW	800 KW	250 Ton (A)	500 Ton (E)	500 Ton (E)	3800 MBH	3800 MBH	
3	1000 KW	-	-	400 Ton (A)	400 Ton (A)	400 Ton (A)	3000 MBH	3000 MBH	
4	1000 KW	800 KW	-	400 Ton (A)	400 Ton (A)	400 Ton (A)	3800 MBH	3800 MBH	
5	800 KW	800 KW	800 KW	400 Ton (A)	400 Ton (A)	400 Ton (A)	3800 MBH	3800 MBH	




























		Normal Operations	No Natural Gas	No Electricity	No Natural Gas, Diesel	No Utilities	No Electricity, Diesel	No Utilities, Limited Diesel	No Utilities, Diesel
	Electric Utility	<	~	×	~	×	×	×	×
	Natural Gas Utility	~	×	~	×	×	~	×	×
	Diesel Supply	~	~	~	×	~	×	~	×
	CHP Engines		2						
	Diesel Generator								
	Cooling Tower								
펕	Critical AHU Fans								
me	Non-Critical AHU Fans								
Equipment	Backup Boiler								
ם	Electric Chillers								
	MRI Chiller								
	OR Chiller								
	Absorption Chiller								
	MRI								
-22	Critical Power Receptacles								
/ice	Life Safety								
Patient Service	Lighting								
Ħ	General Receptacles								
atie	Room Pressurization								
<u>a.</u>	Data Servers								
	OR Cooling								
The second	Vitaban Dafrigaration								
Non- Medical Support	Kitchen Refrigeration								
Non- Medi Supp	Family Area EOC								
2 2 5	EUC	4						()	



















































Acoustics | Patient Room



Source Room	Private PICL Room (473)
Source Room Floor Area	298
Receiver Room	Private PICU Room (472)
Receiver Room Floor Area	304
Common Partition Area	126.5
Receiver Room/Partition Area	2.4

Source Room	Private PICU Room (473)
Source Room Floor Area	298
Receiver Room	Bathroom
Receiver Room Floor Area	53
Common Partition Area	176
Receiver Room/Partition Area	0.3

Source Room	Private PICU Room (473)
Source Room Floor Area	298
Receiver Room Receiver Room Floor Area	Corridor 589
Common Partition Area	164
Receiver Room/Partition Area	3.6

Speech Privacy	9
R_R	4
NC	30
Sound Pressure Level	60
R_S	3

Speech Privacy	15	Spe
R_R	0	R_R
NC	30	NC
Sound Pressure Level	60	Sou Lev
R_S	3	R_S

15
6
40
60
3

Field STC 38

Field STC	48
-----------	----


Field STC	32
-----------	----

STC Adjustment	8
STC	46

STC Adjustment	8
STC	56

STC Adjustment	8
STC	40

Requirements	PICU to PICU	PICU to Corridor	PICU to Bathroom
Confidential & Worst Case	52	40	56
In Between	49	37	53
Normal	46	34	50
Type	Updated: Wall 6	Original	Updated: Wall 5
		Interior Wall Type A6	1/2" Gypsum
	5/8" Gypsum	5/8" Gypsum	1/2" Gypsum
	3-5/8" Metal Stud	6" Metal Stud	3-5/8" Metal Stud
Construction	3" FG	5/8" Gypsum	1.5" FG
	5/8" Gypsum		1/2" Gypsum
			1/2" Gypsum
STC	49	39	55
Price (\$/sqft)	2.72	2.17	4.14



One-Third Octave Band Frequency (Hz)






















If you need more appendix slides, please copy this original slide since the option icons are hyperlinked to the main appendix slide

Lighting/Electrical Appendix | Load Calculations



Estimated Demand Load									
Apparent Power	5655	kVA							
Real Power	4807	kW							

Essential Electrical System Demand									
Apparent Power	4807	kVA							
Real Power	4087	kW							

Generator Load - Paralleled With CHP								
2 Generators 3 Generators								
% Load	kVA	86%	57%					
	kW	94%	63%					

CHP Power Output										
	10	0%	70%							
	kW	kVA	kW	kVA						
C800S	800	1000	560	700						
C1000S	1000	1250	700	875						
Total	1800	2250	1260	1575						

Diesel Fuel Consumption Rate - 2 Generators @ 94% Load Paralleled With CHP

% Load	gph
100%	111.5
94%	105.3
75%	85.7

Fuel Consumption	gph	gpd (24hr)	48 hr	72 hr	96 hr
1 Generator	105.3	2527.4	5054.8	7582.2	10109.6
2 Generators	210.6	5054.8	10109.6	15164.4	20219.1











Lighting/Electrical Appendix | CHP System Energy Costs








Service Charge						
	Flate Rate					
Total Charge	\$115.31					

Combined Heat and Power - Demand Charge								
First 1,000 kW Additional kW								
Total Charge	\$10,170.00	\$30,578.65						

Energy Charge Rates								
First 300 kWh/kW Remaining kWh								
Summer	\$0.0550	\$0.0504						
Winter	\$0.0412	\$0.0360						



Combined Heat and Power - Energy Charge													
	Winter						Summer			Winter			1
	January	February	March	April	May	June	July	August	September	October	November	December	Total
Cooling kWh/month	0.00	0.00	0.00	0.00	50,704.01	79,413.20	118,205.39	74,014.03	46,753.93	3,322.63	0.00	0.00	372,413.20
Hospital kWh/month	1,142,753.42	1,032,164.38	1,142,753.42	1,105,890.41	1,142,753.42	1,105,890.41	1,142,753.42	1,142,753.42	1,105,890.41	1,142,753.42	1,105,890.41	1,142,753.42	13,455,000.00
CHP Production	671,249.12	611,713.92	610,906.12	759,106.89	1,085,476.55	1,166,076.32	1,272,240.00	1,131,519.12	1,016,063.79	799,160.30	609,721.94	612,498.83	10,345,732.91
New kWh/month	471,504.30	420,450.46	531,847.31	346,783.52	107,980.88	19,227.30	0.00	85,248.34	136,580.55	346,915.76	496,168.47	530,254.59	3,492,961.47
Total Charge	\$19,425.98	\$17,322.56	\$21,912.11	\$14,287.48	\$4,448.81	\$1,057.50	\$0.00	\$4,688.66	\$7,511.93	\$14,292.93	\$20,442.14	\$21,846.49	\$147,236.59

= 1	Combined Heat and Power - Total Energy Bill/Month												
	January	February	March	April	May	June	July	August	September	October	November	December	Total
Elec Bill/Month	\$60,289.93	\$58,186.52	\$62,776.07	\$55,151.44	\$45,312.77	\$41,921.46	\$40,863.96	\$45,552.62	\$48,375.89	\$55,156.89	\$61,306.10	\$62,710.45	\$637,604.08
Elec With Primary	10 20.	7.0 X-				10. 10.				1.0	0. 0. 0.		
Service Discount	\$58,481.24	\$56,440.92	\$60,892.78	\$53,496.90	\$43,953.39	\$40,663.82	\$39,638.04	\$44,186.04	\$46,924.61	\$53,502.18	\$59,466.92	\$60,829.13	\$618,475.96
Fuel Bill	\$6,099.85	\$5,558.84	\$5,551.50	\$6,898.24	\$9,864.07	\$10,596.50	\$11,561.24	\$10,282.47	\$9,233.29	\$7,262.22	\$5,540.73	\$5,565.97	\$94,014.91
Total Energy Cost	\$64,581.09	\$61,999.76	\$66,444.28	\$60,395.14	\$53,817.45	\$51,260.32	\$51,199.28	\$54,468.51	\$56,157.90	\$60,764.40	\$65,007.65	\$66,395.10	\$712,490.87












Lighting/Electrical Appendix | CHP and MV TX Payback






MV Transformers Life-Cycle	: Separate Heat
and Power Syst	em
Estimated Annual Elec Bill	\$1,294,848.65
With 3% Discount	\$1,256,003.19
Difference	\$38,845.46
Transformer Investment	\$312,125.00
Payback Period (years)	8.0
Average Lifetime (years)	25
Profitable Life (years)	17.0
Total Profit	\$659,011.48

r rontable Life (years)	17.0
Total Profit	\$659,011.48
MV Transformers Life-Cycle:	Combined Heat
and Power Syste	em
Estimated Annual Elec Bill	\$637,604.08
With 3% Discount	\$618,475.96
Difference	\$19,128.12
Transformer Investment	\$312,125.00
Payback Period (years)	16.3
Average Lifetime (years)	25
Profitable Life (years)	8.7
Total Profit	\$166,078.06















Lighting/Electrical Appendix | Riser Diagram































If you need more appendix slides, please copy this original slide since the option icons are hyperlinked to the main appendix slide

Lighting/Electrical Appendix | Illuminance and LPD Criteria AEI TEAM 02-2018 F U S I D N















Ille	uminance Light	ting Design Crit	eria		
Space	Zone	Task	Recommended Average (lux)		
	Family	Casual Chair	150		
PICU		General	300 (150)		
Patient Room	Patient (Intensive Care)	Examination	1000		
	(interiorve cure)	Nightlight	2		
Table Contain	\A/a nl. Chatian	Day	500		
Team Center	Work Station	Night	300		
	General	Day	100		
Carridan	Circulation	Night	50		
Corridor	Marila Chatian	Day	500		
	Work Station	Night	300		
Formily \\\aitim=	General	Day	200		
Family Waiting	Circulation	Night	100		

Lighting Power Density (LPD) Design Criteria										
Space	Recommended (W/ft²)									
Patient Room	0.62									
Team Center	0.87									
Corridor	0.89									
Family Center	1.07									

Lighting/Electrical Appendix | Illuminance Results
















						(Calculation R	esults													
		# of Calculation Points	Calculation			Fixture			Но	rizontal Illumi	nance			Requirement Check							
Space	Task		Point Spacing (ft)	Boundary Offset (ft)	Fixture Type	Fixture Count	LLF	Average (lux)	Minimum (lux)	Maximum (lux)	Max/Min Ratio	Coefficient of Variation	LPD	Horizontal Illuminance	LPD						
PICU Patient	Examination	27	1	_	G	2	.85	1048	766	1287	1.68	0.15	0.905	PASS	FAIL						
Room	LXammation	27	1	_	D	5	.85	1048	700	1287	1.00	0.15	0.903	1 A33	IAIL						
PICU Patient	General	288	1		G	2	.85	270	103	462	4.49	0.32	0.646	PASS	E A II						
Room	General	288	1	-	D	5	.85	278						PASS	FAIL						
Family Waiting Area	General (Day)	63	2	0.25	В	8	.85	339	176	461	2.6	0.2	0.66	PASS	PASS						
T 0 1	Work Station		100	420	420	120	120	120	2	0.25	J	4	0.85	576	100	042	4.6	0.22	0.0	DAGG	DAGG
Team Center	(Day)	120	2	0.25	В	12	0.85	5/6	198	912	4.6	0.33	0.8	PASS	PASS						
Town Conton	Work Station	120	2	0	J	4	0.1	201	70	420	F 4	0.20	0.0	DACC	DACC						
Team Center	(Night)	120	2	0	В	12	0.72	301	78	420	5.4	0.29	0.8	PASS	PASS						
Camidan	Cananal (Day)) 296	2	0.25	А	127′	0.85	F2	12	101	8.8	0.33	0.40	DACC	DACC						
Corridor	General (Day)	296	2		С	4	0.85	52	12				0.40	PASS	PASS						

Lighting/Electrical Appendix | Patient Room Illuminance




Calculation Points





Grayscale Rendering



Pseudocolor Rendering







Ambient



Examination













	Source	Co	st Per S.F.	% Of Sub-Total	Total Amount	Total Amount	
A. Su	ubstructure						
1010	Proposed, RSMeans, 03 31 13.70 Placing Concrete, 03 31 13.35 Heavyweight Concrete	\$	0.41		\$ 160,869.22		
1020	Auger Cast-in-Place Piles with Pile Caps	\$	13.68		\$ 5,333,872.50		
1030	RSMeans, 30 30 53.40 Concrete In Place (Bldg Construction Costs, p. 76)	\$	0.62	3%	\$ 241,500.00	\$ 5,988,245.91	
2010	Proposed, Basement Excavation	\$	0.65		\$ 252,004.19		
2020	N/A	\$	-				
B. Sh	nell						
B10 S	uperstructure						
1010	RSMeans, B1010 254 W Shape, Composite Deck, & Slab & B101 208 Steel Columns (As	\$	43.80	9%	\$ 17,082,544.64	\$ 19,179,732.04	
1020	RSMeans, B1010 254 W Shape, Composite Deck, & Slab & B101 208 Steel Columns (As	\$	5.38	370	\$ 2,097,187.40	\$ 15,175,732.04	
B20 E	xterior Enclosure						
2010	B2010 146 Metal Siding Panel (22 ga)	\$	6.71		\$ 2,617,888.80		
2020	RSMeans, 08 44 13.10 Glazed Curtain Walls (Facilities Construction Costs, p. 318) (Bas	\$	18.89	5%	\$ 7,368,423.00	\$ 10,036,151.80	
2030	Exterior Doors C1020	\$	0.13		\$ 49,840.00		
B30 R	loofing						
3010	Single ply membrane, stone ballast	\$	2.62	0%	\$ 1,021,800.00	\$ 1,064,700.00	
3020	Roof hatches	\$	0.11	070	\$ 42,900.00	ÿ 1,004,700.00	
C. In	teriors						
1010	Interior Partitions	\$	3.66		\$ 1,427,348.94		
1020	Interior Doors (C1020)	\$	5.42		\$ 2,112,624.00		
1030	Hospital curtains	\$	3.44		\$ 1,341,600.00		
2010	Stair Construction (C2010)	\$	1.86	13%	\$ 727,150.00	\$ 28,954,122.94	+\$10M allowance
3010	65% Paint, 35% ceramic wall tile	\$	20.14		\$ 7,854,600.00		
3020	60% vinyl tile, 20% ceramic, 20% terrazzo	\$	23.90		\$ 9,321,000.00		
3030	Acoustic ceiling tiles on suspended channel grid	\$	15.82		\$ 6,169,800.00		

F. Special Construction

G. Building Sitework
Green Roof

1020 N/A

1040 N/A



D. Se	ervices			
D10 (Conveying			
1010	RSMeans D1010 Elevators & Lefts (Assemblies)	\$ 11.52	2%	\$ 4,494,405.00
1020	N/A	\$ -	270	\$ -
D20 F	Plumbing			
2010	Medical, patient & specialty, supply and drainage	\$ 19.59		\$ 7,639,229.87
2020	Electric water heater	\$ 33.30	10%	\$ 12,987,000.00 \$ 21,968,249.12
2040	Rain water collection system	\$ 3.44		\$ 1,342,019.25
D30 H	HVAC			
3010	Fin Tube Radiation	\$ 5.65		\$ 2,203,155.00
3020	Microturbines & Supplemental Boiler	\$ 14.10		\$ 5,500,000.00
3030	Chillers & Cooling Towers	\$ 2.54	23%	\$ 991,950.00 \$ 49,929,805.00
3050	N/A	\$ -		\$ -
3090	Hot water boilers, ductwork, VAV terminals, ventilation system	\$ 105.73		\$ 41,234,700.00
D40 F	Fire Protection			
4010	Wet pipe sprinkler system	\$ 8.30	2%	\$ 3,237,000.00 \$ 3,829,800.00
4020	Standpipe	\$ 1.52	270	\$ 592,800.00
D50 E	Electrical			
5010	MV Transformers, Switchgears, Busduct	\$ 3.50		\$ 1,363,768.43
5020	Allowance	\$ 71.79	15%	\$ 28,000,000.00 \$ 33,293,961.69
5030	Addressable alarms, emergency lighting, internet and phone wiring	\$ 6.88	15%	\$ 2,684,404.26
5090	Generator, Auto Transfer Switch	\$ 3.19		\$ 1,245,789.00
E. Eq	quipment & Furnishings			
1010	N/A	\$ -		\$ -
1020	N/A	\$ 61.02	120/	\$ 23,799,268.03
1030	N/A	\$ -	13%	\$ 27,600,000.00
2020	N/A	\$ 8.83		\$ 3,444,768.67
	·			· · · · · · · · · · · · · · · · · · ·

\$

0.73

286,000.00 \$

286,000.00













Sub-Total	\$ 216,625,173.50		\$ 216,625,173.50	
Contractor Fees (Contingency: 6%, General Cond.: 6%, Overhead: 4%, Profit: 7%)	\$ 49,823,789.91			
Architect Fees (9%)	\$ 23,980,406.71			
Total Building Cost	\$ 290,429,370.11			


























		Area of	Area of Metal	Total Area of	Cos	st/SF of		
	Total	Glazing	Panels	Finishes	Fir	nishes	Cost Incre	ase
Option 1: (E) Average, single glazed	\$ 9,521,991.40	56,530	64,290	120,820	\$	78.81		
(I) Average, double glazed, 22 g								
insulated metal panel							\$ 464,320.40	5%
Option 2: (E) Average, double	\$ 9,986,311.80	56,530	64,290	120,820	\$	82.65		
glazed (I) Average, double glazed,								
22 g insulated metal panel							\$ 5,713,816.80	57%
Option 3: (E) Average, double	\$ 15,700,128.60	56,530	64,290	120,820	\$	129.95		·
glazed (I) FEMA Rated glazing, 22 g								
insulated metal panel								

Construction Appendix | Structural Costs













Auger Cast-in-Place								
Piles	Daily Output	Unit	Material	Total	Count	Depth	Depth (V.L.F.)	Total
18" diameter, 0.065								
C.Y./L.F.	900	V.L.F.	\$100.00	\$100.00	406	81	32886	\$3,288,600.00
				·	128	103	13184	\$1,318,400.00
							Total	\$4,607,000.00

A1010 250 Pile Caps, RSMeans Assemblies Costs (p. 7)												
							Cost Each					
	No. Piles	Size (ft-in x ft-in x in)	Pile Capacity (ton)	Column Size (in)	Column Load (k)	Mat.	Inst.	Total	Count	Total		
6600	14	11-6x10-9x55	80	29	2155	\$3,425.00	\$2,375.00	\$5,800.00	60	\$348,000.00		
7000	18	13-0x11-6x56	80	33	2776	\$4,375.00	\$2,925.00	\$7,300.00	29	\$211,700.00		
7150	20	14-6x11-6x52	40	24	1491	\$4,698.75	\$2,900.00	\$7,598.75	22	\$167,172.50		
										\$726,872.50		

Total w/ Pile Caps \$5,333,872.50

Construction Appendix | Structural Costs

















			31 63 26.	13 Fixed End	Caisson P	iles (Bldg C	onstruction	n Costs p. 645)					
	Open style, machine drilled, to 50' deep,												
	in soft rocks and medium hard shales,	Crew	Daily Output	Labor Hours	Unit	Material	Labor	Equipment	Total	Count	Depth	Depth (V.L.F.)	Total
2700	36" diameter, 0.262 C.Y./L.F.	B-49	15	5.867	V.L.F.	\$ 37.00	\$ 275.00	\$ 239.00	\$ 551.00	16	85	1360	\$ 749,360.00
										39	107	4173	\$ 2,299,323.00
3000	72" diameter, 1.05 C.Y./L.F.	B-49	6	14.667	V.L.F.	\$ 149.00	\$690.00	\$ 600.00	\$1,439.00	28	85	2380	\$ 3,424,820.00
										8	107	856	\$ 1,231,784.00
Total \$ 7,705,287.00													
3900	3900 For 50' to 100' deep, add V.L.F. 7%								Total	\$ 8,244,657.09			



Project Complete

D days


























































































































Goal Development
















Design Development

































Design Strategizing







































Workflow Planning | Bluebeam

















Bluebeam Studio

Bluebeam Studio, in collaboration with Box, was employed for document storage, sharing, and as a file backup system.















Team Structure


















Disaster Preparedness


















Lighting














Allowat

Not Per

15%



Interactive Wall













Distance	Degree of Opening Protection	Allowable area
3'-5'	Unprotected, Not Sprinkle red	Not Permitted
5'-10'	Unprotected, Not Sprinkle red	15%